

EC Attestation of Conformity

No.: M8 03 01 48034 004



Havalandırma Endüstri
San. ve Tic. Ltd. Sti.
Büyükdere Cad. Ali Kaya Sk

Levent/Istanbul
Turkey

Product: Machinery
(Unit Heater)

Model: HAD-HAT 11, 12, 13, 21, 22, 23, 31, 32, 33

Parameters: Rated voltage: 230 V
Rated frequency: 50 Hz
Class of protection: I
Degree of protection: IP 24

The equipment complies with the principal protection requirements of the Machinery Directive (Directive 98/37/EEC relating to machinery) based on a voluntary test.

This attestation applies only to the particular sample of the product provided for testing and certification. The detailed test results and all standards used as well as the operation mode are listed in

Test report no. 70032497

Test standards: EN 60204-1:1997, 98/37/EG

This attestation is released with the above mentioned attestation number by the Certification Body of TÜV PRODUCT SERVICE. It does not permit the use of a TÜV PRODUCT SERVICE certification mark.

After preparation of the necessary technical documentation as well as the conformity declaration the CE marking as shown below can be affixed on the equipment. Other relevant Directives have to be observed.

Department: STGEMA / clh
Date: 29-Jan-2003

